





State Water Resources Control Board

December 23, 2016

(Via email and Certified Mail)
CERTIFIED MAIL
NO. 7015 1520 0001 8017 1337

Mr. Curtis Smith
Superintendent
City of Irvine Operation Support Facility
6427 Oak Canyon Road
Irvine California, 92618
cusmith@cityofirvine.org

SUBJECT:

NOTICE OF VIOLATION; UNDERGROUND STORAGE TANK SYSTEMS

LOCATED AT CITY OF IRVINE OPERATION SUPPORT FACILITY,

6427 OAK CANYON ROAD, IRVINE

Dear Mr. Smith:

As part of an initiative by the State Water Resources Control Board (State Water Board) to ensure compliance at government-owned and/or operated underground storage tank (UST) facilities in California, the State Water Board staff inspected the UST(s) at your facility on December 6, 2016, pursuant to authority under Health and Safety Code (H&SC), chapter 6.7, section 25289.

The State Water Board has identified the following violations pursuant to H&SC, chapter 6.7, and California Code of Regulations (CCR), title 23, chapter 16:

No.	Violation	Tank	Start Date	Stop Date	Regulation
1	Failure to Maintain Monitoring and Testing Records Onsite – The 2014 annual monitoring certifications, spill containment tests, line leak detector tests, and the most recent secondary containment testing report were not present at the time of inspection. These testing documents must be kept onsite for three years.	All	December 6, 2016	Ongoing	H&SC 25293; 23 CCR 2712(b)
2	Failure to Perform Designated UST Operator Inspection – The monthly DO inspection report for December 2015 was not present at the time of inspection.	All	December 1, 2015	December 31, 2015	23 CCR 2715(c)

You are directed to correct the ongoing violations and submit compliance documentation to the State Water Board and Orange County Health Care Agency within sixty (60) days from the date of this letter. Have your Designated Operator make specific notations in the

Office of Enforcement | 801 K Street, Suite 2300 | Sacramento, CA 95814 | 916.341.5272

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

next monthly designated operator report indicating the ongoing violations have been corrected. The monthly designated operator report and any associated photos must be submitted as proof of compliance.

Please send all compliance documentation to the following:

State Water Board

Ms. Rebecca Green
UST Enforcement Unit
Office of Enforcement
State Water Resources Control Board
801 K Street, 23rd Floor
Sacramento, California 95814
rebecca.green@waterboards.ca.gov

Local CUPA

Ms. Christine Lane
Program Manager
Orange County Health Care Agency
1241 East Dyer Road #120
Santa Ana, California 92705
clane@ochca.com

Pursuant to Health and Safety Code, chapter 6.7, section 25299, the owner and operator of the tank(s) are liable for a penalty of \$500 to \$5,000 per tank, per day of violation. These penalties will continue to accrue until the violations have been corrected.

If you have any questions, please contact me at (916) 341-5551, or by email at amantha.henkel@waterboards.ca.gov.

Sincerely,

Amantha Henkel

Senior Environmental Scientist

UST Enforcement Unit

Office of Enforcement

cc: (via email only)

Ms. Christine Lane REHS
Program Manager
Hazardous Materials Surveillance Section
Environmental Health Division
clane@ochca.com